


GENERAL NOTES:

- A. This section is to be used only for parking lots or as approved by the City Engineer.
- B. When curb is placed adjacent to existing or future irrigated landscape area, PCC shall extend down as shown for moisture barrier. Any alternate moisture barrier shall be approved by the City.
- C. When curb is not located as in Note B, depth may be reduced.
- D. Expansion joints shall be placed at corners, BC's & EC's, and at 33 feet max. spacing.
- E. See Engineering Standard #4110 for notes regarding required pavement removal & repair.

REVISIONS	BY	APP	DATE
Allow Class 2R Base	DVB	BL	11-08
Revise re-bar specs	JDL	WAP	11-98
Extend curb slope	JDL	WAP	5-98
STANDARD CURRENT AS OF:		January 2010	



CURB