



NOTES:

- ① See Standard Specification 86-2.05 for information regarding conduit materials, use, and installation.
- ② See Engineering Standards 6020, 6025, and 6030, and Section 19 of the Standard Specifications for requirements regarding trench backfill and restoration of surface improvements.
- ③ Depth of Conduit shall conform to the following:
 Min. 18" for signal wire
 Min. 24" for Electrical Service and fiberoptic wire
 Min. 30" for all other wire types
- ④ Trenches for conduit shall be backfilled with 10" of Initial Backfill and the remaining depth with Subsequent Backfill.

REVISIONS	BY	APP	DATE
<i>New Standard</i>	<i>DVB</i>	<i>BL</i>	<i>11-07</i>
STANDARD CURRENT AS OF:		January 2010	



**TRENCH DETAIL #4
CONDUIT TRENCH**