


**NOTES:**

- ① 2" BALL VALVE, JONES J-1921 SG OR FORD B41-777G, OR APPROVED EQUAL.
- ② POLYETHYLENE TUBING, SDR-9, 200 psi WESFLEX OR EQUAL.
- ③ 2 EACH, 2" x 4" x 12" REDWOOD RISER SUPPORTS.

*NOTE: THIS STANDARD TO BE USED ONLY WHERE FIRE DEPT. APPROVED "TELEPHONE LEASE LINE ALARM SYSTEM" IS INSTALLED. OTHERWISE, A DETECTOR CHECK ASSEMBLY IS REQUIRED.*

REVISIONS	BY	APP	DATE
Tracing Wire Note	MH	BL	11-09
New border	JDL	WAP	9-97
Compression fitting	SR	JDW	10-03
STANDARD CURRENT AS OF:		January 2010	



**FIRE SPRINKLER VALVE AND WELL 2"**

6520