


GENERAL NOTES:

- A. Fire line shall be tested in accordance with the Section 76, "WATERLINES" of the City Standard Specifications. NO CONNECTION MAY BE MADE UNTIL WATER SAMPLES HAVE BEEN TESTED AND APPROVED.
- B. Location of fire sprinkler riser shall be approved by the Fire Department.
- C. Materials shall be UL listed for fire service.
- D. Wrap bolts with 6 mil plastic sheathing prior to placement of thrust block(s).
- E. All fittings and risers shall be ductile iron internally cement lined for fire service and wrapped with two layers of UPC listed plastic tape (minimum 40 mil) or coated with Henry's #204 plastic roof cement or an approved equal.

REVISIONS	BY	APP	DATE
Use of tracer wire	JDL	WAP	1-00
New border	JDL	WAP	9-97
Note changes per FD	JDL	WAP	9-97
STANDARD CURRENT AS OF:		January 2010	



**FIRE MAIN
BUILDING CONNECTION**